

Confirmation

LEED

On 26 August 2015, Eurofins Product Testing A/S received a sample of a sealant with the product name:

HIT-RE 500 V3

supplied by

Hilti Entwicklungsgesellschaft GmbH

The sample was supplied as being representative of the manufactured product, and it has been tested as a Multipurpose Construction Adhesive in accordance with the relevant ISO 16000, ISO 11890-1, ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2015-00258501_H_EN and G24556_02).

The test results of the tested sealant indicate that the product qualifies for LEED v4 and LEED 2009 specifications on VOC emissions and VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- The requirements of CDPH-IAQ (California Department of Public Health); and a TVOC below 0.5 mg/m³ in both office and class room.

VOC content specifications in LEED EQ credit "Low-emitting products":

- The requirements of SCAQMD rule 1168 (2005)

14 October 2015



Lise L. Clement
Chemist



Janne R. Norup
Chemist